

**TESTING FOR THE VERIFICATION OF COMPLIANCE OF
PV INVERTER WITH :
ENGINEERING RECOMMENDATION G98 ISSUE 1-
AMENDMENT 6 SEPTEMBER 2021,
REQUIREMENTS FOR THE CONNECTION OF FULLY TYPE
TESTED MICRO-GENERATORS (UP TO AND INCLUDING
16 A PER PHASE) IN PARALLEL WITH PUBLIC LOW
VOLTAGE DISTRIBUTION NETWORKS ON OR AFTER 27
APRIL 2019**

Test Report Number: **GZES240300433002**

Type: Hybrid Inverter

Tested Model: ED3600A

Variant Models: /

APPLICANT

Hired by: Huizhou Foryou Optoelectronics Technology Co., Ltd

Address: Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China

TESTING LABORATORY

Name: SGS-CSTC Standards Technical Services Co., Ltd.
Guangzhou Branch

Address: 198 Kezhu Road, Science City, Economic & Technology Development Area, Guangzhou, Guangdong, China

Conducted (tested) by: Doris Tao
(Project Engineer)



Doris Tao

Approved by: Roger Hu
(Technical Reviewer)

Roger Hu

Date of issue: 2024-05-16

Number of pages: 115

Important Note:

- This document is issued by the Company under its General Conditions of service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. **Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes.** The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client. This document cannot be reproduced except in full, without prior approval of the Company.

Test Report Historical Revision:

Test Report Version	Date	Resume
GZES240300433002	2024-05-16	<p>First issuance</p> <p>Remarks: According to the declaration from the applicant, the only difference between the EUT (test samples in this report) and testing sample of report GZES220801676702, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch as below: -Update applicant, manufacturer, trademark, models name, label, appearance and equipment type ect.</p> <p>After evaluation, no clause needs to retest. All test data originate from the report GZES220801676702, which was issued by SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.</p>

INDEX

1	SCOPE	4
2	GENERAL INFORMATION.....	5
2.1	Testing Period and Climatic conditions	5
2.2	Equipment under Testing	5
2.3	Manufacturer and Factory information	8
2.4	Test equipment list	8
2.5	Measurement uncertainty.....	9
2.6	Test set up of the different standard	10
2.7	Definitions.....	11
3	RESUME OF TEST RESULTS.....	12
4	TEST RESULTS	13
4.1	Operating Range	13
4.2	Power Quality	17
4.2.1	Current Harmonics	17
4.2.2	Voltage fluctuations and Flicker	19
4.2.3	DC Injection.....	22
4.2.4	Power Factor	23
4.3	Protection	25
4.3.1	Frequency tests.....	25
4.3.2	Voltage tests.....	46
4.3.3	Loss of Mains test	67
4.3.4	Frequency change, Vector Shift Stability test and RoCoF Stability test	88
4.4	Limited Frequency Sensitive Mode - Overfrequency test.....	91
4.5	Power output with falling frequency test	93
4.6	Re-connection timer	94
4.6.1	Voltage Reconnection Conditions	94
4.6.2	Frequency Reconnection Conditions	96
4.7	Fault level contribution	99
4.8	Self-Monitoring solid state switching.....	103
4.9	Electromagnetic Compatibility (EMC)	103
4.10	Logic Interface.....	104
4.11	Cyber security	105
5	PICTURES.....	106
6	ELECTRICAL SCHEME	115

1 SCOPE

SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch has been contract by Huizhou Foryou Optoelectronics Technology Co., Ltd, in order to perform the testing according the “Engineering Recommendation G98 Issue 1 - Amendment 6 September 2021, Requirements For The Connection Of Fully Type Tested Micro-Generators (Up To And Including 16 A Per Phase) In Parallel With Public Low Voltage Distribution Networks On Or After 27 April 2019”.

2 GENERAL INFORMATION

2.1 TESTING PERIOD AND CLIMATIC CONDITIONS

The necessary testing has been performed along between the 28th of February and 13th of April of 2023. All the tests and checks have been performed at 25 ± 5°C, 96 kPa ± 10 kPa and 50% RH ± 10% RH).

SITE TEST

Name.....: **Dongguan BALUN Testing Technology Co., Ltd.**
 Address: Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China.

2.2 EQUIPMENT UNDER TESTING

Apparatus type: Hybrid Inverter
 Installation: Fixed installation
 Manufacturer: **Huizhou Foryou Optoelectronics Technology Co., Ltd**
 Address: Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China
 Trade mark: **ADAYO**
 Model / Type reference: ED3600A
 Serial Number: DN22222222
 Software Version: GA01.001-001-001
 Rated Characteristics: DC input: 150-500 V, Max. 2× 15 A
 AC output: L/N/PE 230 V, 50 Hz, 15.6 A (17.2 A), 3600 W

Date of manufacturing: 2020

Test item particulars

Input: DC
 Output.....: AC
 Class of protection against electric shock...: Class I
 Degree of protection against moisture: IP 65
 Type of connection to the main supply: TN
 Cooling group: See model list on page 8
 Modular: No
 Internal Transformer.....: No

Copy of marking plate (representative) :

Model Name:	ADAYO	ED3600A
PV Input:		
PV max power :		5200W
PV max Voltage:		500Vdc
PV input voltage range		150-500Vdc
MPPT Voltage rang		120-430Vdc
Max input Current per string of tracker A/tracker B:		15A/15A
Starting Volatge:		150Vdc
AC Output:		
Normal operating volatge:		230Vac
Max operating currnt:		17.2Aac
Normal operating frequency:		50Hz
Maximum power:		3600W
Power Factor Range:		±0.8
Back-Up Output:		
Output Power:		3600W
Output Voltage:	230Vac ±2%, 50Hz (60Hz Optional)±0.2%	
Battery:		
Battery voltage range :		41.6V-58.5V
Maximum battery current(charge/dischage):		80A/85A
General Data:		
Dimension(H/W/D):		230*350*580mm
Weight		25Kg
Transformer		Transformerless
Protect Class:		IP65
Cooling		Natural cooling
Interface:		USB/RS485/CAN
Display:		LCD
This Grid support interactive inverter complies with IEC 62109-1:2010, IEC 62109-2:2011 EN IEC 61000-6-1:2019 EN IEC 61000-6-3:2021 EN 50549-1:2019 VDE-AR-N 4105:2018 G99:2021 & G98:2021 NTs:2021-09 & UEN 217002:2020 CEI-021:2019		

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.
3. Labels of other models are as the same with **ED3600A**'s except the parameters of rating.

Equipment Under Testing:

- **ED3600A**

The variants models are:

- N/A

The variants models have been included in this test report without tests because the following features don't change regarding to the tested model:

- Same connection system and hardware topology
- Same control algorithm.
- Output power within 1/√10 and 2 times of the rated output power or the EUT or Modular inverters.
- Same Firmware Version

Following table shows the full ratings of the all models referenced in this report, marked in **bold letters** the ones subjected to testing:

Model	ED3600A
PV Input	
Max. input voltage	500 Vdc
Start-up operating voltage	150 Vdc
Rated input voltage	360 Vdc
MPPT operating voltage range	150-500 Vdc
Full power MPPT voltage range	150-430 Vdc
Max. input current	15 A/15 A
Max. short current	19.8 A/19.8 A
Battery Input	
operating voltage range	41.6V-58.5 Vdc
Maximum battery charge current	80 A
Maximum battery discharge current)	85 A
AC Output	
Nominal grid voltage	L/N/PE, 230 V
Nominal grid frequency	50 Hz
Rated AC power	3600 W
Max. AC power	3960 VA
Rated AC current	15.6 A
Max. AC current	17.2 A
Output power factor	1 default (adjustable+/-0.8)
General Data	
Operating temperature range	-30 °C ~ +60 °C
Protection degree	IP65
Protective class	Class I
Cooling method	Natural Cooling
Topology	Transformerless

The results obtained apply only to the particular sample tested that is the subject of the present test report. The most unfavorable result values of the verifications and tests performed are contained herein.

Throughout this report a point (comma) is used as the decimal separator.

2.3 MANUFACTURER AND FACTORY INFORMATION

Manufacturer Name..... : **Huizhou Foryou Optoelectronics Technology Co., Ltd**
 Manufacturer Address..... : Building 6, B Area, No.1 North Shangxia Road, Dongjiang High-Tech Industry Park, Huizhou, Guangdong, China
 Factory Name..... : **Shenzhen Donnergy Power Technology Co. Ltd .**
 Factory Address : A305, Zongtai E-commerce Science and Innovation Park, Shiyan Street, Baoan District, Shenzhen, China.

2.4 TEST EQUIPMENT LIST

From	No.	Equipment Name	Trademark / Model No.	Equipment No.	Calibration Period
Balun	1	Power analyzer	ZLG/ PA6000H	BZ-DGD- L059	2022/10/13 to 2023/10/12
	2	Current probe	HIOKI/ CT6863-05	BZ-DGD- L026-1	2023/02/20 to 2024/02/19
	3	Current probe	HIOKI/ CT6863-05	BZ-DGD- L026-2	2023/02/20 to 2024/02/19
	4	Current probe	HIOKI/ CT6863-05	BZ-DGD- L026-4	2023/02/20 to 2024/02/19
	5	Voltage probe	CYBERTEK/ VP5200A	BZ-DGD-L241-1	2022/03/01 to 2023/02/28 2023/03/09 to 2024/03/08
	6	Voltage probe	CYBERTEK/ VP5200A	BZ-DGD-L241-2	2022/03/01 to 2023/02/28 2023/03/09 to 2024/03/08
	7	Voltage probe	CYBERTEK/ VP5200A	BZ-DGD-L241-3	2022/03/01 to 2023/02/28 2023/03/09 to 2024/03/08
	8	Temperature & Humidity meter	CEM/ DT-322	BZ-DGD-L005	2022/03/01 to 2023/02/28 2023/03/13 to 2024/03/12
	9	Digital oscilloscope	TEKTRONIX/ MS04054B	BZ-DGD-L064	2022/03/01 to 2023/02/28 2023/03/07 to 2024/03/06
	10	Power Analyzer	DEWETRON / TRIONet	BZ-DGD-L305	2022/08/18 to 2023/08/17
SGS	11	True RMS Multimeter	Fluke/187	GZE012-16	2022/05/21 to 2023/05/20

2.5 MEASUREMENT UNCERTAINTY

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.


Magnitude	Uncertainty
Voltage measurement	$\pm 0.05\%$
Current measurement	$\pm 0.05\%$
Frequency measurement	$\pm 0.001\text{ Hz}$
Time measurement	$\pm 0.001\text{ s}$
Power measurement	$\pm 0.5\%$
Phase Angle	$\pm 0.1^\circ$
Temperature	$\pm 3^\circ\text{ C}$

Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the solicitant.

Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered.

2.6 TEST SET UP OF THE DIFFERENT STANDARD

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shows in chapter 2.3. Current and voltage clamps have been connected to the inverter input / output for all the tests. All the tests described in the following pages have used this specified test setup.

The test bench used includes:

EQUIPMENT	MARK / MODEL	RATED CHARACTERISTICS	OWNER / ID. CODE
AC source	KEWELL / KACM-75-33	60 kVA max. 45-65 Hz	BZ-DGD-L193
PV source	CHROMA / Chroma 6215011-1000s	15 kVA max.	BZ-DGD-L009
RLC load	QunLing / ACTL-3820	68 kW, 68 kvar	BZ-DGD-L063

2.7 Definitions

EUT	Equipment Under Testing	Hz	Hertz
A	Ampere	V	Volt
VAr	Volt-Ampere reactive	W	Watt
EMC	Electromagnetic Compatibility	p.u	Per unit
Un	Nominal Voltage	Pn	Nominal Active Power
In	Nominal Current	Qn	Nominal Reactive Power
Ia	Active Current	Sn	Nominal Apparent Power
Ir	Reactive Current	THD	Total Harmonic Distortion
I _h	Harmonic Current	TDD	Total Demand Distortion
PWHD	Partial Weighted Harmonic Distortion	PLT	Severity of Flicker Long-Term
PST	Severity of Flicker Short-Term	d(t)	Variation of Voltage
d max	Maximum Absolute Value of Voltage Variation	OV	Over Voltage
UV	Under Voltage	OF	Over Frequency
		UF	Under Frequency

3 RESUME OF TEST RESULTS

INTERPRETATION KEYS

Test object does meet the requirement **P** Pass
 Test object does not meet the requirement..... **F** Fails
 Test case does not apply to the test object **N/A** Not applicable
 To make a reference to a table or an annex. See additional sheet
 To indicate that the test has not been realized **N/R** Not realized

STANDAARD CLAUSE	STANDARD REQUIREMENTS		RESULT
	G98 Issue 1 Amendment 3 March 2019		
	TEST	REMARKS	
EN 50438 D.3.1.	Operating Range		P
EREC G98 Annex A1 A1.3.1	Harmonics		P
EREC G98 Annex A1 A1.3.3	Voltage fluctuations and Flicker		P
EN 50438 Annex D.3.10	DC injection		P
EN 50538 Annex D.3.4.1	Power factor		P
EREC G98 Annex A1 A.1.2.3	Frequency tests		P
EREC G98 Annex A1 A.1.2.2	Voltage tests		P
BS EN 62116	Loss of Mains test		P
EREC G98 Annex A1 A.1.2.6	Frequency change, Vector Shift Stability test		P
EREC G98 Annex A1 A.1.2.6	Frequency change, RoCoF Stability test		P
EN 50438 Annex D.3.3	Overfrequency test		P
EN 50438 Annex D.3.2	Power output with falling frequency test		P
EN 50438 Annex A12	Re-connection timer.		P
EREC G98 Annex A1 A.1.3.5	Fault level contribution		P
EREC G98 Annex A1 A.1.3.6	Self-Monitoring solid state switching	No solid state switching devices	N/A
EREC G98 Annex A1 A.1.3.7	Electromagnetic Compatibility (EMC)		N/R (¹)
EREC G98 9.4.4	Logic Interface		P
EREC G98 9.7	Cyber security		P

The compliances with these requirements are stated in the following test reports:

(¹)EMC Test Report: Test Report no. GZEM220800488101C11, issued by SGS-CST Standards Technical Services Co., Ltd. Guangzhou Branch on May 06 of 2024.

4 TEST RESULTS

4.1 Operating Range

This test should be carried out as specified in EN 50438 D.3.1.

Active Power shall be recorded every second. The tests will verify that the Micro-generator can operate within the required ranges for the specified period of time.

The Interface Protection shall be disabled during the tests.

In case of a PV Micro-generator the PV primary source may be replaced by a DC source.

In case of a full converter Micro-generator (eg wind) the primary source and the prime mover Inverter/rectifier may be replaced by a DC source.

In case of a DFIG Micro-generator the mechanical drive system may be replaced by a test bench motor.

Test 1

Voltage = 85% of nominal (195.5 V)

Frequency = 47.0 Hz

Power factor = 1

Period of test 20 seconds

Test 2:

Voltage = 85% of nominal (195.5 V)

Frequency = 47.5 Hz

Power factor = 1

Period of test 90 minutes

Test 3:

Voltage = 110% of nominal (253 V).

Frequency = 51.5 Hz

Power factor = 1

Period of test 90 minutes

Test 4:

Voltage = 110% of nominal (253 V).

Frequency = 52.0 Hz

Power factor = 1

Period of test 15 minutes

Test 5

Voltage = 100% of nominal (230 V).

Frequency = 50.0 Hz

Power factor = 1



Period of test 90 minutes

Test 6 RoCoF withstand


Confirm that the **Micro-Generating Plant** is capable of staying connected to the **Distribution Network** and operate at rates of change of frequency up to 1 Hzs⁻¹ as measured over a period of 500 ms.

This is not expected to be demonstrated on site.


Test results are graphically shown in following pages.




Test 3




Test 4



Test 5



Test 6



4.2 POWER QUALITY

4.2.1 Current Harmonics

The tests should be carried out as specified in BS EN 61000-3-2 and can be undertaken with a fixed source of energy at two power levels firstly between 45 and 55% and at 100% of Registered Capacity. The test requirements are specified in Annex A1 A.1.3.1 (Inverter connected) or Annex A2 A.2.3.1 (Synchronous).

Measures have been repeated at 50%P_n and 100%P_n.


Following tables show the test results:

Micro-generator rating per phase (rpp)			3.6	kW			
Harmonic	At 45-55% of Registered Capacity		100% of Registered Capacity				
	Measured Value MV in Amps	Ih(%)	Measured Value MV in Amps	Ih(%)	Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above	
2	0.019	0.116	0.038	0.236	1.080		
3	0.060	0.373	0.112	0.700	2.300		
4	0.008	0.051	0.017	0.105	0.430		
5	0.050	0.311	0.079	0.494	1.140		
6	0.005	0.031	0.015	0.091	0.300		
7	0.042	0.262	0.069	0.430	0.770		
8	0.002	0.010	0.006	0.036	0.230		
9	0.038	0.240	0.055	0.342	0.400		
10	0.002	0.015	0.009	0.055	0.184		
11	0.030	0.189	0.045	0.283	0.330		
12	0.002	0.011	0.007	0.041	0.153		
13	0.026	0.166	0.014	0.089	0.210		
14	0.001	0.004	0.002	0.014	0.131		
15	0.021	0.133	0.011	0.072	0.150		
16	0.001	0.008	0.003	0.022	0.115		
17	0.017	0.105	0.019	0.121	0.132		
18	0.001	0.006	0.002	0.015	0.102		
19	0.015	0.095	0.016	0.100	0.118		
20	0.001	0.005	0.002	0.014	0.092		
21	0.010	0.064	0.010	0.065	0.107	0.160	
22	0.001	0.004	0.002	0.010	0.084		
23	0.010	0.065	0.007	0.042	0.098	0.147	
24	0.001	0.006	0.001	0.008	0.077		
25	0.007	0.046	0.006	0.037	0.090	0.135	
26	0.001	0.006	0.001	0.006	0.071		
27	0.006	0.037	0.003	0.021	0.083	0.124	
28	0.001	0.007	0.001	0.004	0.066		
29	0.005	0.031	0.003	0.021	0.078	0.117	
30	0.001	0.005	0.001	0.008	0.061		
31	0.003	0.020	0.003	0.016	0.073	0.109	
32	0.001	0.006	0.001	0.004	0.058		
33	0.003	0.021	0.002	0.013	0.068	0.102	
34	0.001	0.006	0.001	0.005	0.054		
35	0.002	0.010	0.003	0.020	0.064	0.096	
36	0.001	0.004	0.001	0.006	0.051		
37	0.002	0.014	0.003	0.018	0.061	0.091	

ENA Engineering Recommendation G98 Issue 1 Amendment 6 September 2021

38	0.001	0.005	0.001	0.004	0.048	
39	0.002	0.010	0.003	0.017	0.058	0.087
40	0.001	0.007	0.002	0.013	0.046	

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.



4.2.2 Voltage fluctuations and Flicker

These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (Inverter connected) or Annex A2 A.2.3.3 (Synchronous).

The measurements of voltage fluctuations have been measured according to the standard, at 100 % of the nominal power value of the inverter.

The test impedance is recorded in the table below:

Test Impedance	R	0.24	Ω	X	0.15	Ω
Standard Impedance	R	0.24	Ω	X	0.15	Ω
Maximum Impedance	R	0.24	Ω	X	0.15	Ω

Starting operation and Stopping operation			
Pbin (%)	100%		
	Limit	Starting measured values	Stopping measured values
PST	≤ 1	0.131	0.034
PLT	≤ 0.65	0.105	0.105
dc	≤ 3.30%	0.250%	0.000%
d(t)	≤ 3.30%	0.000%	0.000%
dmax	4%	0.345%	0.000%

As it can be seen in the next screenshots, this test has two steps:

1. Starting operation
2. Stopping operation

All values are the most unfavorable of the two steps.

Starting operation and Stopping operation

100% Pn

Flicker Mode
Flicker

Range Over
U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter
 AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count 2/2 Complete

Interval 00:00s/10:00s

Element 1

Volt Range 300 V/50Hz Element1 Judgement Pass

Un (U1) 230.539V Total Judgement Pass

Freq (U1) 50.000Hz (Element1,2,3)

Dmin 0.10%

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.00%	1.00	0.65 N:2
No. 1	0.250 Pass	0.345 Pass	0.0 Pass	0.131 Pass	
2	0.000 Pass	0.000 Pass	0.0 Pass	0.034 Pass	
Result	Pass	Pass	Pass	Pass	0.105 Pass

ΣA(3P4W)

U1 300 V
I1 50 A
Sync Src: U1
Integral: Reset

U2 300 V
I2 50 A
Sync Src: U1
Integral: Reset

U3 300 V
I3 50 A
Sync Src: U1
Integral: Reset

Element 4

U4 1000 V
I4 50 A
Sync Src: U1
Integral: Reset

Element 5

U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

Running operation 2 hours		
Pbin (%)	100%	
	Limit	Measured values
PST	≤ 1	0.078
PLT	≤ 0.65	0.068
dc	≤ 3.30%	0.127%
d(t)	≤ 3.30%	0.000%
dmax	4%	0.203%

As it can be seen in the next screenshots is running operation. The values took of Pst and Plt are the most unfavorable of the twelve steps.

Running operation
100% Pn

Flicker Mode
Flicker

Range Over
U1 U2 U3 U4 U5 U6 U7
I1 I2 I3 I4 I5 I6 I7

SCL Line Filter
AVG Freq Filter

CH: 1 2 3
4 5 6 7

Count12/12 Complete

Interval00:00s/10:00s

Element	1				
Volt Range	600 V/50Hz	Element1	Judgement	Pass	
Un (U1)	230.674V	Total	Judgement	Pass	
Freq (U1)	50.000Hz	(Element1,2,3)			
Dmin	0.10%				

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65
No. 1	0.110 Pass	0.187 Pass	0.0 Pass	0.075 Pass	N:12
2	0.110 Pass	0.185 Pass	0.0 Pass	0.076 Pass	
3	0.107 Pass	0.180 Pass	0.0 Pass	0.078 Pass	
4	0.108 Pass	0.170 Pass	0.0 Pass	0.078 Pass	
5	0.101 Pass	0.165 Pass	0.0 Pass	0.070 Pass	
6	0.104 Pass	0.166 Pass	0.0 Pass	0.064 Pass	
7	0.104 Pass	0.162 Pass	0.0 Pass	0.065 Pass	
8	0.101 Pass	0.203 Pass	0.0 Pass	0.059 Pass	
9	0.127 Pass	0.186 Pass	0.0 Pass	0.059 Pass	
10	0.115 Pass	0.168 Pass	0.0 Pass	0.058 Pass	
11	0.115 Pass	0.182 Pass	0.0 Pass	0.060 Pass	
12	0.107 Pass	0.168 Pass	0.0 Pass	0.065 Pass	
Result	Pass	Pass	Pass	Pass	0.068 Pass

ΣA(3P4W)
U1 600 V
I1 50 A
Sync Src: U1
Integral: Reset

Element 4
U4 1000 V
I4 50 A
Sync Src: U1
Integral: Reset


Element 5
U5 1000 V
I5 5 A
Sync Src: U1
Integral: Reset

4.2.3 DC Injection

The DC component shall be measured under steady-state conditions for the following power levels: 20 %, 50 %, 75 %, and 100 % of nominal power with a tolerance of ± 5 % of nominal power and as far as adjustable for the tested micro-generator. These tests should be undertaken in accordance with Annex A1.3.4.

Following tables show the test results:

Power quality – DC injection: This test should be carried out in accordance with EN 50438 Annex D.3.10				
Test power level	20%	50%	75%	100%
Recorded value in Amps	0.024	0.016	0.015	0.013
as % of rated AC current	0.153	0.102	0.096	0.083
Limit	0.25%	0.25%	0.25%	0.25%




4.2.4 Power Factor



This test shall be carried out in accordance with EN 50538 Annex D.3.4.1 but with nominal voltage -6% and +10%. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test.

The following table shows the test results at required voltage levels:

	216.2 V	230 V	253 V
20% of Registered Capacity	0.956	0.976	0.961
50% of Registered Capacity	0.996	0.994	0.986
75% of Registered Capacity	0.993	0.988	0.994
100% of Registered Capacity	0.996	0.994	0.986
Limit	>0.95	>0.95	>0.95

Test results are graphically shown below.





4.3 PROTECTION

4.3.1 Frequency tests

These tests should be carried out in accordance with EN 50438 Annex D.2.4 and the notes in EREC G98 Annex A1 A.1.2.3 (Inverter connected) or Annex A2 A.2.2.3 (Synchronous).


To establish a trip frequency, the test frequency should be applied in a slow ramp rate of less than 0.1 Hz/s, or if this is not possible in steps of 0.05 Hz for a duration that is longer than the trip time delay.

To establish the trip time, the test frequency should be applied starting from 0.3 Hz below or above the recorded trip frequency and should be changed to 0.3 Hz above or below the recorded trip frequency in a single step. For each trip setting five tests shall be carried out.



Following tables show the test results:

Function	Setting		Trip test (5 times)		"No trip tests"	
	Frequency	Time delay	Frequency (Hz)	Time delay (s)	Frequency /time	Confirm no trip
U/F stage 1	47.5 Hz	20 s	47.50	20.090	47.7 Hz / 30 s	Pass
			47.50	20.090		
			47.50	20.070		
			47.50	20.070		
			47.50	20.040		
U/F stage 2	47 Hz	0.5 s	47.00	0.545	47.2 Hz / 19.5 s	Pass
			47.00	0.560		
			47.00	0.555		
			47.00	0.555		
			47.00	0.540		
					46.8 Hz / 0.45 s	Pass
O/F stage 1	52 Hz	0.5 s	52.01	0.575	51.8 Hz / 120 s	Pass
			52.02	0.575		
			52.02	0.585		
			52.02	0.565		
			52.02	0.570		
					52.2 Hz / 0.45 s	Pass


Test results are graphically shown below.




U/F stage 1-2





U/F stage 1-3





M505104 Thu April 13 14:37:26 2023




U/F stage 1-4




U/F stage 1-5





U/F stage 2-1





MSO5104 Thu April 13 14:46:42 2023





U/F stage 2-2





U/F stage 2-3





U/F stage 2-4





U/F stage 2-5





O/F stage 1-1





O/F stage 1-2





O/F stage 1-3




O/F stage 1-4



O/F stage 1-5



No trip tests - 47.7Hz



MSO5104 Mon March 27 10:33:56 2023

RIGOL STOP H 4.00s 200kSa/s 10Mpts Measure STOP/RUN D -20.0s

Roll Mode

光标

AX: -37.76s
 AY: -18V
 BX: -7.76s
 BY: -36.66V
 ΔX: 30s
 ΔY: -18.66V
 1/ΔX: 33.33mHz



最大值1	最小值1	峰值2	最大值2	有效值1	正占空比1
365.66V	-411.37V	55.867A	18.622A	228.32V	49.618%

1 1.00kV +1.16kV 2 100A -84.0A 3 1.00V +2.36V 4 20.0V +47.2V



0 1 2 3 4 5 6 7
8 9 10 11 12 13 14 15

10:33



No trip tests – 47.2Hz





No trip tests – 46.8Hz



No trip tests - 51.8Hz



No trip tests – 52.2Hz



4.3.2 Voltage tests

To establish the certified trip voltage, the test voltage should be applied in steps of $\pm 0.5\%$ of setting for a duration that is longer than the trip time delay.



To establish the certified trip time, the test voltage should be applied starting from $\pm 1.8\%$ below the certified trip voltage in a step of at least $\pm 0.5\%$ of setting for a duration that is longer than the trip time delay. For each trip setting five tests shall be carried out.

Following tables show the test results:


Function	Setting		Trip test		"No trip tests"	
	Voltage	Time delay	Voltage (V)	Time delay (s)	Voltage /time	Confirm no trip
U/V	184 V	2.5 s	184.17	2.530	188 V / 5.00 s	Pass
			184.37	2.535		
			184.35	2.505		
			184.16	2.530		
			184.23	2.510		
					180 V / 2.45 s	Pass
O/V stage 1	262.2 V	1.0 s	261.82	1.060	258.2 V / 5.00 s	Pass
			262.03	1.055		
			262.17	1.055		
			262.13	1.045		
			262.35	1.055		
O/V stage 2	273.7 V	0.5 s	274.34	0.555	269.7 V / 0.95 s	Pass
			274.98	0.585		
			273.91	0.570		
			273.84	0.555		
			274.05	0.560		
					277.7 V / 0.45 s	Pass

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Test results are graphically shown in following pages.



U/V -2



M505104 Thu April 13 15:18:15 2023

RIGOL STOP H 500ms 2MSa/s 10Mpts Measure STOP/RUN D -2.50s

光标

- AX: -3.06s
- AY: -750V
- BX: -525ms
- BY: 1.333kV
- ΔX: 2.535s
- ΔY: 2.083kV
- 1/ΔX: 394.4mHz



有效值1	峰值1	最大值1	有效值2	峰值2	最大值2
185.98V	548.41V	251.35V	17.955A	55.880A	23.283A

1 500V +120V 2 50.0A -100A 3 10.0V +400mV 4 20.0V -12.8V



0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15

15:17



U/V -3





U/V -4





U/V -5





O/V stage 1-1





O/V stage 1-2





O/V stage 1-3





O/V stage 1-4





O/V stage 1-5







O/V stage 2-1





O/V stage 2-2















No trip tests – 188V





No trip tests – 180V





No trip tests – 258.2V



No trip tests – 269.7V



No trip tests – 277.7V



4.3.3 Loss of Mains test

For PV Inverters shall be tested in accordance with BS EN 62116.

The maximum trip time is 0.5 s.


Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies.

Following tables show the test results:


ENA Engineering Recommendation G98 Issue 1 Amendment 6 September 2021


Table: tested condition and trip time						P
No.	P _{EUT} (% of EUT rating)	Reactive load (% of normal)	P _{AC}	Q _{AC}	Trip time(s)	Which load is selected to be adjusted (R or L)
Test condition A						
1	100	100	0	0	0.452	--
2	100	100	-5	-5	0.250	R/L
3	100	100	-5	0	0.236	R
4	100	100	-5	+5	0.247	R/L
5	100	100	0	-5	0.443	L
6	100	100	0	+5	0.253	L
7	100	100	+5	-5	0.239	R/L
8	100	100	+5	0	0.232	R
9	100	100	+5	+5	0.279	R/L
10	100	100	-10	+10	--	R/L
11	100	100	-5	+10	--	R/L
12	100	100	0	+10	--	L
13	100	100	+10	+10	--	R/L
14	100	100	+10	+5	--	R/L
15	100	100	+10	0	--	R
16	100	100	+10	-5	--	R/L
17	100	100	+10	-10	--	R/L
18	100	100	+5	-10	--	R/L
19	100	100	+5	+10	--	R/L
20	100	100	0	-10	--	L
21	100	100	-5	-10	--	R/L
22	100	100	-10	-10	--	R/L
23	100	100	-10	-5	--	R/L
24	100	100	-10	0	--	R
25	100	100	-10	+5	--	R/L
Test condition B						
1	66	66	0	0	0.251	--
2	66	66	0	-5	0.232	L
3	66	66	0	-4	0.237	L
4	66	66	0	-3	0.232	L
5	66	66	0	-2	0.243	L
6	66	66	0	-1	0.244	L
7	66	66	0	1	0.268	L
8	66	66	0	2	0.333	L
9	66	66	0	3	0.246	L
10	66	66	0	4	0.234	L
11	66	66	0	5	0.230	L
Test condition C						
1	33	33	0	0	0.249	--
2	33	33	0	-5	0.241	L
3	33	33	0	-4	0.243	L
4	33	33	0	-3	0.245	L
5	33	33	0	-2	0.238	L
6	33	33	0	-1	0.232	L
7	33	33	0	1	0.240	L
8	33	33	0	2	0.232	L
9	33	33	0	3	0.228	L
10	33	33	0	4	0.230	L
11	33	33	0	5	0.228	L


Test results are graphically shown in following pages.





Test Condition C




























































4.3.4 Frequency change, Vector Shift Stability test and RoCoF Stability test

Four tests are required to be carried out with all protection functions enabled including loss of mains. For each stability test the Micro-generator should not trip during the test.

For the step change test the Micro-generator should be operated with a measurable output at the start frequency and then a vector shift should be applied by extending or reducing the time of a single cycle with subsequent cycles returning to the start frequency. The start frequency should then be maintained for a period of at least 10 s to complete the test. The Micro-generator should not trip during this test.


For frequency drift tests the Micro-generator should be operated with a measurable output at the start frequency and then the frequency changed in a ramp function at 0.95 Hzs⁻¹ to the end frequency. On reaching the end frequency it should be maintained for a period of at least 10 s. The Micro-generator should not trip during this test.

Test results are graphically shown in following pages.


Protection – Frequency change, Vector Shift Stability test: This test should be carried out in accordance with EREC G98 Annex A1 A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous).

	Start Frequency	Change	Confirm no trip
Positive Vector Shift	49.0 Hz	+50 degrees	Pass
Negative Vector Shift	50.0 Hz	- 50 degrees	Pass

Positive Vector Shift:




Negative Vector Shift:




Protection – Frequency change, RoCoF Stability test: The requirement is specified in section 11.3, test procedure in Annex A.1.2.6 (Inverter connected) or Annex A2 A.2.2.6 (Synchronous).

Ramp range	Test frequency ramp:	Test Duration	Confirm no trip
49.0 Hz to 51.0 Hz	+0.95 Hzs ⁻¹	2.30 s	Pass
51.0 Hz to 49.0 Hz	-0.95 Hzs ⁻¹	2.24 s	Pass

+0.95 Hz/s:



-0.95 Hz/s:



4.4 Limited Frequency Sensitive Mode - Overfrequency test

The test serves to verify the active power reduction of the micro-generator at over-frequency. We perform the test according to EN 50438 Annex D.3.3 Power response to over-frequency.

The tests for providing evidence of the frequency dependent active power feed-in of the micro-generator shall be carried out on a network simulator.


The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%.

Following tables show the test results:


Test sequence at Registered Capacity >80%	Measured Active Power Output (W)	Frequency (Hz)	Primary Power Source	Active Power Gradient(%)
Step a) 50.00 Hz \pm 0.01 Hz	3650.28	50.00	DC Source	N/A
Step b) 50.45 Hz \pm 0.05 Hz	3622.38	50.45		12.9
Step c) 50.70 Hz \pm 0.10 Hz	3437.32	50.70		10.1
Step d) 51.15 Hz \pm 0.05 Hz	3108.77	51.15		10.0
Step e) 50.70 Hz \pm 0.10 Hz	3437.52	50.70		10.2
Step f) 50.45 Hz \pm 0.05 Hz	3622.86	50.45		13.1
Step g) 50.00 Hz \pm 0.01 Hz	3649.96	50.00		N/A

Test sequence at Registered Capacity 40% - 60%	Measured Active Power Output (W)	Frequency (Hz)	Primary Power Source	Active Power Gradient(%)
Step a) 50.00 Hz \pm 0.01 Hz	1804.66	50.00	DC Source	N/A
Step b) 50.45 Hz \pm 0.05 Hz	1767.43	50.45		9.7
Step c) 50.70 Hz \pm 0.10 Hz	1583.32	50.70		9.8
Step d) 51.15 Hz \pm 0.05 Hz	1252.24	51.15		9.8
Step e) 50.70 Hz \pm 0.10 Hz	1573.04	50.71		9.3
Step f) 50.45 Hz \pm 0.05 Hz	1767.42	50.45		9.7
Step g) 50.00 Hz \pm 0.01 Hz	1804.50	50.00		N/A

Test results are graphically shown in following pages.



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.



Remark: Test for frequency threshold 50.4Hz with droop 10%, intentional delay is setting to 0s.


4.5 Power output with falling frequency test

This test should be carried out in accordance with EN 50438 Annex D.3.2 active power feed-in at under-frequency.

Test sequence	Measured Active Power Output (W)	Frequency (Hz)	Primary power source
Test a) 50 Hz \pm 0.01 Hz	3650.25	50.00	-
Test b) Point between 49.5 Hz and 49.6 Hz	3648.76	49.50	-
Test c) Point between 47.5 Hz and 47.6 Hz	3645.45	47.50	-

NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes

Test results are graphically shown in following pages.



4.6 Re-connection timer


Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2. These tests should be undertaken in accordance with Annex A.2.2.5.

4.6.1 Voltage Reconnection Conditions

The following table detail tests performed.

Test at	Time delay setting(s)	Measured delay(s)	Checks on no reconnection when voltage is brought to just outside stage 1 limits of table 1.	
UV	60.0	74.0	At 266.2V	At 180.0 V
OV	60.0	74.2		
Confirmation that the Micro-generator does not re-connect.			Not reconnection	Not reconnection

Test results are graphically shown below.





4.6.2 Frequency Reconnection Conditions

The following table detail tests performed.

Test at	Time delay setting(s)	Measured delay(s)	Checks on no reconnection when frequency is brought to just outside stage 1 limits of table 1.	
UF	60	77.8	At 47.4Hz	At 52.1Hz
OF	60	78.8		
Confirmation that the Micro-generator does not re-connect.			Not reconnection	Not reconnection

Test results are graphically shown below.









4.7 Fault level contribution


These tests shall be carried out in accordance with EREC G98 Annex A1 A.1.3.5 (Inverter connected) and Annex A2 A.2.3.4 (Synchronous).

They have been performed different short circuit tests that are detailed in the table and pictures below.

Short circuit current		
Time after fault	Volts(V)	Amps(A)
20ms	0.075	-0.401
100ms	0.060	-0.405
250ms	0.046	-0.403
500ms	0.044	-0.410
Time to trip	0.004	In seconds







4.8 SELF-MONITORING SOLID STATE SWITCHING

The evaluation of this point has been made according to EREC G98 Annex A1 A.1.3.6.

This test does not apply because in the inverter there are not solid-state switching devices.

4.9 ELECTROMAGNETIC COMPATIBILITY (EMC)

All equipment shall conform to the generic EMC standards: BS EN61000-6-3: Electromagnetic Compatibility, Generic Emission Standard; and BS EN61000-6-1: Electromagnetic Compatibility, Generic Immunity Standard.

The compliances with these requirements are stated in the following test report:

- EN IEC 61000-6-3: 2011; EN IEC 61000-6-1: 2019: Test Report no. GZEM220800488101C11, issued by SGS-CST Standards Technical Services Co., Ltd. Guangzhou Branch on May 06 of 2024.


4.10 LOGIC INTERFACE.

Confirm that an input port is provided and can be used to shut down the module.

The evaluation of this point has been made according to Clause 9.4.3 of the standard.

Power Generating Modules connected to the DNO's Distribution Network shall be equipped with a logic interface (input port) in order to cease Active Power output within 5 s following an instruction being received at the input port.

Test results are graphically shown as below.



4.11 CYBER SECURITY

Confirm that the Manufacturer or Installer of the Micro-generator has provided a statement describing how the Micro-generator has been designed to comply with cyber security requirements, as detailed in 9.7.

The Manufacturer of the Micro-generator has provided a statement describing how the Micro-generator has been designed to comply with cyber security requirements in 9.7.

Additional comments.

The DNO logic interface will take the form of a simple binary output that can be operated by the switch. When the switch is turned off the Power Generating Module can operate normally. When the switch is turned on the Power Generating Module will reduce its Active Power to zero within 5 s. The signal from the Power Generating Module that is being switched is DC (maximum value 3.3Vdc)

5 PICTURES

Front view



Back Side



Connection interface




Top Side




External grounding




General Internal view of inverter



Front of main power board



Back of main power board



Front of Bus capacitance board




Back of Bus capacitance board




Front of capacitance board




Back of capacitance board




Front of control board




Back of control board



Front of display board




Back of control board



Serial Number



6 ELECTRICAL SCHEME



-----END OF REPORT-----